2024 Annual Drinking Water Quality Report Town of Iva #0410001

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water is purchased from the Starr-Iva Water and Sewer District who purchases their water from Anderson Regional. If you have any questions about this report or concerning your water utility, please contact Bobby Gentry at 864-348-6193. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month at 10:00 AM at the Iva Town Hall. If you do not have internet access, please contact Bobby Gentry at 864-348-6193 to make arrangements to review this document.

The Town of Iva routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2024. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose

Our raw water sources are most susceptible to contamination from runoff or environmental conditions.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

ppm: parts per million, or milligrams per liter (mg/L) ppb: parts per billion, or micrograms per liter (μ g/L)

NA: not applicable ND: Not detected

a health risk.

NR: Monitoring not required but recommended.

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MNR: Monitored Not Regulated

MPL: State Assigned Maximum Permissible Level



TEST RESULTS

Town of Iva (SC0410001)

Lead and Copper									
Contaminant	Violation Y/N	90 th percentile	Unit Measurement	Action Level	Sites over action level	Likely Source of Contamination			
Copper (2022)	N	0.021 Range 0-0.061	ppm	1.3	0	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives			
Lead (2022)	N	5 Range 0-10	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits			
	Disinfectants and Disinfection By-Products (2023)								
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination			
Chlorine (20240	N	1.0 Range 0.44-1.23	ppm	4	4	Water additive used to control microbes			
Haloacetic acids (HAAs) (2024)	N	22.0 Range 9.0519- 30.3955	ppb	60	N/a	By-product of drinking water disinfectant			
TTHM Total trihalomethane (2024)	N	41 Range 15.802- 52.7308	ppb	80	n/a	By-product of drinking water chlorination			

Anderson Regional Joint (SC0420011)

Contaminants (unit of measure)	MCLG or MRDLG	MCL, TT, or MRDL	Detect in Your Water	Range	Violation (Yes or No)	Typical Source
Nitrate (ppm) (2024)	10	10	0.12	0.12- 0.12	No	Runoff from fertilizer use. Erosion of natural deposits.
Fluoride (ppm) (2024)	4	4	0	0-0	No	Runoff from fertilizer use. Erosion of natural deposits.
Sodium (ppm) [unregulated] (2024)	NA	NA	5.5	5.5-5.5	No	Naturally occurring.

Turbidity

	Limit (treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.070 NTU	N	Soil runoff
Lowest monthly % meeting limit	0.3 NTU	100.000%	N	Soil runoff



We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Iva is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Town of Iva at 864-348-6193. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at http://www.epa.gov/safewater/lead.

A lead service line inventory was completed throughout our system, in 2024. For more information on this inventory please contact us at 864-348-6193.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

